

ORDINANCE NO. 930

AN ORDINANCE AMENDING THE CODE OF ORDINANCES OF THE CITY OF LE MARS, IOWA, BY AMENDING SECTION 155.10, SUBSECTION 4, PERTAINING TO THE NATIONAL ELECTRIC CODE

Be It Enacted by the City Council of the City of Le Mars, Iowa:

SECTION 1. SUBSECTION MODIFIED. Section 155.10, Subsection 4 of the Code of Ordinances of the City of Le Mars, Iowa, is repealed and the following adopted in lieu thereof:

4. *National Electrical Code, 2014 Edition*, published by the National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471, is adopted with the following amendments:
 - Add the following exceptions to section 210.8, paragraph (A), subparagraph (2):
 - a. Exception No. 1 to (2): Receptacles that are not readily accessible.
 - b. Exception No. 2 to (2): A single receptacle or a duplex receptacle for two appliances located within dedicated space for each appliance that, in normal use, is not easily moved from one place to another and that is cord-and-plug connected in accordance with 400.7(A)(6), (A)(7), or (A)(8).
 - c. Receptacles installed under the exceptions to 210.8(A)(2) shall not be considered as meeting the requirements of 210.52(G).
 - Add the following exceptions to section 210.8, paragraph (A), subparagraph (5):
 - a. Exception No. 2 to (5): Receptacles that are not readily accessible.
 - b. Exception No. 3 to (5): A single receptacle or a duplex receptacle for two appliances located within dedicated space for each appliance that, in normal use, is not easily moved from one place to another and that is cord-and-plug connected in accordance with 400.7(A)(6), (A)(7), or (A)(8).
 - c. Receptacles installed under the exceptions to 210.8(A)(5) shall not be considered as meeting the requirements of 210.52(G).
 - Delete section 210.12(B).
 - Delete the exception to section 220.12 and insert in lieu thereof the following exception: EXCEPTION: Where the building is designed and constructed to comply with an energy code adopted by the local authority, the lighting load shall be permitted to be calculated at the values specified in the energy code.
 - Delete section 406.4(D)(4).

All Ordinances or parts of Ordinances in conflict with the provisions of this Ordinance are hereby repealed.

This Ordinance shall be in full force and effect from and after its passage, approval and publication as required by law.

PASSED AND APPROVED this 19th day of January, 2016.

ATTEST:

Dick Kirchoff, Mayor

Beverly Langel, City Clerk

CLERK'S CERTIFICATE

STATE OF IOWA)

* ss:

PLYMOUTH COUNTY)

I, Beverly Langel, City Clerk of the City of Le Mars, Iowa certify that the foregoing Ordinance was passed by a duly constituted quorum of the City Council of the City of Le Mars, Iowa, meeting in regular session on the 19th day of January, 2016 and that said Ordinance was

published in the official City newspaper, the Le Mars Daily Sentinel, in its issue date this _____ day of _____, 2016.

Beverly Langel, City Clerk

SEAL

First Reading: 1/05/16

Second Reading: 1/19/16

Third Reading: Waived